



Kendall County Health Department
Environmental Health Unit
811 W. John Street, Yorkville, IL 60560
Phone: 630.553.9100 Ext. 8026 Fax: 630.553.9603

HOLE SIZE AND VOLUME TABLE

3/8th inch Coarse Grade Wyoming Bentonite

| Hole Diameter | Hole Volume (ft ³ /foot) | Pounds of Bentonite to fill One Foot | One Bag Fills | Bags to Fill 100' |
|---------------|-------------------------------------|--------------------------------------|---------------|-------------------|
| 4" | 0.087 | 6.3 | 7.9 | 12.6 |
| 5" | 0.136 | 9.8 | 5.1 | 19.6 |
| 6" | 0.196 | 14.1 | 3.5 | 28.2 |